

VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

watstp@Frontiernet.net or watstp1@villageofwaterville.org

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

MONTHLY VILLAGE BOARD REPORT

JULY 2018

REPORTING PERIOD

AVERAGE FLOW: 0.157 M.G.D.

GALLONS OF WASTEWATER PROCESSED: 4.9 million gal.

TOTAL LABOR EXPENDED: 316 man-hours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 615 cu.ft.

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVE

TOTAL PRECIPITATION: 6.3" RAIN

REMARKS OR COMMENTS

- Yearly maintenance done of truck and skid steer
- Aries sewer camera demo its trailer and unit for us
- Belt press 27,500 gallons of biosolids into compost
- Egan Environmental cleaned the wet well, return sludge box and center of clarifier and haul to Rome
- DEC inspection on our solid waste facility (compost) everything was OK, we must end our land application permit if we are no longer land applying our sludge.
- Activity notification form was sent to the DEC on their request to terminate our land application permit because of not using it for the last 2 years
- 23 Morrisville College ETC Basic Operators students toured the facility
- Met with Mike Harrington (Lamott Engineering) and 3 representatives of Jade Stone (electrical and plumbing engineers) on our upcoming project

