

VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

watstp@Frontiernet.net or watstp1@villageofwaterville.org

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

MONTHLY VILLAGE BOARD REPORT

OCTOBER

REPORTING PERIOD

AVERAGE FLOW: 0.159 m.g.d.

GALLONS OF WASTEWATER PROCESSED: 4.93 million gal.

TOTAL LABOR EXPENDED: 364 man-hours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 473 cu.ft.

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVED

TOTAL PRECIPITATION: 6.5" RAIN

REMARKS OR COMMENTS

- Submitted comprehensive Review with special sampling results to D.E.C. for our SPDES permit review
- 25 Morrisville College ETC activated sludge students toured the facility
- Steve Grimm NYRWA helped get Jamie enrolled to the netDMR computer program
- Mike attended class in Syracuse on workforce development workshop for contact hrs.
- Louie attended Water University class in Wampsville for contact hrs.
- Belt pressed 31,500 gallons of biosolids into compost pile
- 13 DEC personnel from Morrisville College ETC toured the facility