

VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

watstp@Frontiernet.net or watstp1@villageofwaterville.org

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

MONTHLY VILLAGE BOARD REPORT

JUNE 2018

REPORTING PERIOD

AVERAGE FLOW: 0.136 M.G.D.

GALLONS OF WASTEWATER PROCESSED: 4.1 million gal.

TOTAL LABOR EXPENDED: 324 man-hours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 471 cu.ft.

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVE

TOTAL PRECIPITATION: 3.6" RAIN

REMARKS OR COMMENTS

- 18 students from Morrisville College ETC toured the facility for their activated sludge class
- NY Warn/Alert new notification site became active on June 13, 2018
- Serviced all the motors and equipment for the process units
- Mike participated in a NYSDEC NY Warn/Alert training webinar
- Belt pressed 29,750 gallons of sludge into compost pile
- Meet with Mike Harrington on the status of our upcoming project and its funding and availability of money for this year
- Topographical survey was done of the facility for the upcoming project

