

# VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

[watstp@Frontiernet.net](mailto:watstp@Frontiernet.net) or [watstp1@villageofwaterville.org](mailto:watstp1@villageofwaterville.org)

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

## MONTHLY VILLAGE BOARD REPORT

**January 2018**

REPORTING PERIOD

AVERAGE FLOW: **0.174 M.G.D.**

GALLONS OF WASTEWATER PROCESSED: **5.39 M.G.**

TOTAL LABOR EXPENDED: **352 hours**

BIOSOLIDS/COMPOST REMOVED FROM PLANT: **0 removed**

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM  
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

**All SPEDES limits and levels were achieved**

### REMARKS OR COMMENTS

One (1) compost pile was made

VFD problem with #2 Influent pump, waiting for repair to be done by AquaLogics Systems