

VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

watstp@Frontiernet.net or watstp1@villageofwaterville.org

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

MONTHLY VILLAGE BOARD REPORT

SEPTEMBER 2018

REPORTING PERIOD

AVERAGE FLOW: 0.146 M.G.D.

GALLONS OF WASTEWATER PROCESSED: 4.4 million gal.

TOTAL LABOR EXPENDED: 300 hours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 216 cu.ft.

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVED

TOTAL PRECIPITATION: 7.2" RAIN

REMARKS OR COMMENTS

- Fire alarm system was inspected and passed
- Village Board toured the facility for upcoming project
- Gas meter calibrated to factory settings (2 times/year)
- Confined Space SCBA's tested and passed
- Sampled for DEC for their comprehensive review of our SPDES permit
- Mike attended Chlorine & Disinfection training for 6 contact hours
- 25 Morrisville College ETC Basic Operators students toured the facility.
- Stream bank repair completed

