

VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

watstp@Frontiernet.net or watstp1@villageofwaterville.org

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

MONTHLY VILLAGE BOARD REPORT

FEBRUARY 2018

REPORTING PERIOD

AVERAGE FLOW: 0.150 M.G.D.

GALLONS OF WASTEWATER PROCESSED: 4.2 million gal.

TOTAL LABOR EXPENDED: 326 man-hours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 144 cu.ft.

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVE

TOTAL PRECIPITATION: TOTAL 35.7" 34" SNOW & 1.7" RAIN

REMARKS OR COMMENTS

- NYSDEC annual compost submitted
- #2 Influent pump V.F.D. was repaired by AquaLogics System & is working good
- Aries Video Sewer Inspection camera & equipment was demo by J & J Equipment, very nice unit

- 2017 YEAR END TOTALS:
 - Average flow for 2017 was 0.159 m.g.d.
 - Processed 58 million gallons of wastewater
 - Total precipitation 175.8", 125.8" snow, 50 "rain

- COMPOST 2017
 - We had 143 compost pickups from the facility

 - Gave away 168 cu.Yds. of finished compost

 - Processed 280,250 gallons of liquid biosolids/ sludge from digester into 35,069 lbs. of belt press biosolids which was made into class 1compost

 - By making and giving away compost the Village saved approx. \$12,286.00 vs taking the sludge to the landfill at Ava (tipping fees & hauling)