

VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

watstp@Frontiernet.net or watstp1@villageofwaterville.org

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

MONTHLY VILLAGE BOARD REPORT

APRIL 2018

REPORTING PERIOD

AVERAGE FLOW: 0.160 M.G.D.

GALLONS OF WASTEWATER PROCESSED: 4.8 million gal.

TOTAL LABOR EXPENDED: 360 manhours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 331 cu.ft.

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVED

TOTAL PRECIPITATION: TOTAL 12.1" 8.1" SNOW & 4.0" RAIN

REMARKS OR COMMENTS

- Activated Sludge class from Morrisville College ETC toured facility (20 students)
- Received large amount of new woodchips from T/O Marshall, T/O Kirkland, V/O Waterville, V/O Clinton and Hutch Tree Service
- Mike & Louie attended OSHA training in New Hartford
- Mike attended Basic Lab. Training for contact hrs. in Mexico
- Belt Pressed 36,250 gallons of sludge into compost pile
- Eggen Environment pumped the wet well 2400 gal. and hauled and dumped to C/O Rome Plant
- Demo sewer video camera, CYNCON equipment, Rapid View unit, very nice unit but quite pricey
- Had flow meter annual calibration done
- Had backflow preventer tested by NYRWA, passed
- Month of April was the coolest ever since I have been at the STP, the natural gas reading of 357 cu. ft. was the most I ever recorded since 1984.