

# VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

[watstp@Frontiernet.net](mailto:watstp@Frontiernet.net) or [watstp1@villageofwaterville.org](mailto:watstp1@villageofwaterville.org)

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

## MONTHLY VILLAGE BOARD REPORT

### AUGUST

---

#### REPORTING PERIOD

AVERAGE FLOW: 0.131 M.G.D.

GALLONS OF WASTEWATER PROCESSED: 4.1 million gal.

TOTAL LABOR EXPENDED: 378 man-hours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 453 cu.ft.

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM  
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVED

TOTAL PRECIPITATION: 5.1" RAIN

## **REMARKS OR COMMENTS**

- Aqua Logic repaired VFD on Influent pump controls
- 14 Morrisville College ETC Activated Sludge students toured the facility
- NYMIR inspection everything OK
- Sewer camera demo by CYNCON equipment
- All safety data sheets and safety policies yearly updates completed