

# VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.

WATERVILLE, NEW YORK 13480

PHONE 315-841-4445 FAX 315-841-8007

[watstp@Frontiernet.net](mailto:watstp@Frontiernet.net) or [watstp1@villageofwaterville.org](mailto:watstp1@villageofwaterville.org)

CHIEF OPERATOR – LOUIS LANGONE

ASSISTANT OPERATOR – MIKE KELLY

## MONTHLY VILLAGE BOARD REPORT

JANUARY 2019

---

### REPORTING PERIOD

AVERAGE FLOW: 0.157 M.G.D.

GALLONS OF WASTEWATER PROCESSED: 4.87 million gal.

TOTAL LABOR EXPENDED: 382 man-hours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 0

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM  
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVED

TOTAL PRECIPITATION: 39.6" 2.6" rain / 37" snow

## **REMARKS OR COMMENTS**

- Routine generator maintenance done
- John O'Connell – of Koester Associates spoke with us
- Met with NYSEG rep. on larger electrical service for the upgrade
- Sewer camera and trailer arrived and factory startup training was done
- Power outage caused blower #3 VFD to burn out and caused the scum beach in clarifier to freeze up
- Belt press 25,250 gallons of biosolids into and compost pile
- 23 Morrisville College ETC activated students toured the facility

### **2018 YEAR END TOTALS**

- Average Flow for 2018 was 0.16 m.g.d
- Processed 58 millions gallons of wastewater
- Total precipitation 200.6” 154.8” snow, 45.8” rain

### **COMPOST 2018**

- We had 143 compost pickups from the facility
- Gave away 172 cu. yds. of finished compost
- Processed 279,500 gallons of liquid biosolids/sludge from the digester into 34,975 lbs. of belt press biosolids which was made into class 1 compost
- By making and giving away compost the Village saved approx.. \$11,534.00 vs. taking the sludge to the landfill at Ava (tipping fees & hauling)

