

VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.
WATERVILLE, NEW YORK 13480
PHONE 315-841-4445 FAX 315-841-8007

watstp2@villageofwaterville.org
CHIEF OPERATOR – MIKE KELLY

MONTHLY VILLAGE BOARD REPORT JULY 2019

REPORTING PERIOD

AVERAGE FLOW: .140 MGD

GALLONS OF WASTEWATER PROCESSED: 4.3 MGD

TOTAL LABOR EXPENDED: 218 Man hours

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 29.5
CU.YD

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:
ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVED

TOTAL PRECIPITATION: 6.0 Rain

REMARKS OR COMMENTS

- Belt press 42000 gallons of biosolids into compost pile
- Aaron and Michael attended a training class
- RSP pump control lost memory/ Aqualogics had to come reprogram VFD for pumps.
- Generator got service
- Took compost and belt press sample to lab
- Extra sample done for the DEC as per the permit