

VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.
WATERVILLE, NEW YORK 13480
PHONE 315-841-4445 FAX 315-841-8007

watstp2@villageofwaterville.org

CHIEF OPERATOR – MIKE KELLY

MONTHLY VILLAGE BOARD REPORT

February 2020

REPORTING PERIOD

AVERAGE FLOW: .152 MGD

GALLONS OF WASTEWATER PROCESSED: 4.4 MGD

TOTAL LABOR EXPENDED: 218 MAN HOURS

BIOSOLIDS/COMPOST REMOVED FROM PLANT: 3.7 cu.yds

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:

ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVED

TOTAL PRECIPITATION: 1.9" RAIN 40" SNOW

REMARKS OR COMMENTS

The wet well pumps lost their program when the generator was tested. Aqualogics had to reprogram the controls.

They also found that the battery backup unit for the controls went bad so they replaced with a new one. This new battery can be used when the new system goes in.

-The first customer came for compost.

- Belt pressed 36000 gallons of biosolids into a compost pile