

# VILLAGE OF WATERVILLE WASTEWATER TREATMENT FACILITY



122 BARTON AVE.  
WATERVILLE, NEW YORK 13480  
PHONE 315-841-4445 FAX 315-841-8007

[watstp2@villageofwaterville.org](mailto:watstp2@villageofwaterville.org)

CHIEF OPERATOR – MIKE KELLY

## MONTHLY VILLAGE BOARD REPORT

APRIL 2020

---

### REPORTING PERIOD

AVERAGE FLOW: 0.159

GALLONS OF WASTEWATER PROCESSED: 4.77 MGD

TOTAL LABOR EXPENDED: 216 MANHOURS

BIOSOLIDS/COMPOST REMOVED FROM PLANT:  
57.19 CUBIC FEET

NEW YORK STATE POLLUTANT ELIMINATION SYSTEM  
(SPDES) DISCHARGE PERMIT LIMITS AND LEVEL:  
ALL SPEDES AND DISCHARGE LIMITS WERE ACHIEVED

TOTAL PRECIPITATION: 1.8" RAIN 13" SNOW

## **REMARKS OR COMMENTS**

Belt press 53500 gallons of biosolids into a compost pile

Screened 2 compost piles

Lab scale was calibrated